



#### NOTES:

1. ALL CORNERS OF LIFT STATION TRACT SHALL HAVE SURVEY MARKERS IN PLACE AND ALL UNPAVED AREAS SODDED PRIOR TO FINAL INSPECTION.
2. VALVE VAULT SHALL HAVE TWO (2) COATS OF TAR EPOXY 9 MILS THICK INSIDE AND OUTSIDE.
3. ENGINEER SHALL DETERMINE STRUCTURAL STEEL REINFORCEMENT AND SUBMIT APPROVED SHOP DRAWINGS TO SEMINOLE COUNTY.
4. PRESSURE GAUGES SHALL BE STAINLESS STEEL, RED VALVE SERIES 40 PRESSURE SENSOR (OR EQUAL), 4 1/2" DIAL AND HAVE SUFFICIENT RANGE TO READ 20% ABOVE THE DESIGN HEAD CONDITION.
5. DIMENSION "R" SHALL BE ADEQUATE TO ALLOW THE REMOVAL OF THE CHECK VALVE SPINDLES BUT IN NO CASE LESS THAN 12 INCHES.
6. ONLY THERMAL OR ELECTRO-THERMO FUSION OF HDPE IS ALLOWED
7. ALL FITTINGS SHALL BE RESTRAINED AS REQUIRED.

PUMP STATION PLAN

PLAN  
NTS

SEM. CO OCT 2012  
315